



Standard AIR CONTAMINANT DISCHARGE PERMIT

Department of Environmental Quality
Northwest Region
700 NE Multomnah St., Suite 600
Portland, Oregon 97232
(503) 229-5263

This permit is being issued in accordance with the provisions of ORS 468A.040
and based on the land use compatibility findings included in the permit record.

ISSUED TO: Intel Corporation 3100 NE Shute Road M/S RS5-115 Hillsboro, OR 97124	INFORMATION RELIED UPON: Application No.: 30867 Date Received: 08/21/2019
PLANT SITE LOCATIONS: Aloha Campus 3585 SW 198th Avenue Aloha, OR 97007 Ronler Acres Campus 2501 NE Century Blvd. Hillsboro, OR 97124	LAND USE COMPATIBILITY FINDING: Aloha Campus Issued by: Washington County Dated: 09/20/1991, 2/19/2014 Ronler Acres Campus Issued by: City of Hillsboro Dated: 12/19/2014

ISSUED BY THE DEPARTMENT OF ENVIRONMENTAL QUALITY



Matt Hoffman, Northwest Region Air Quality Manager

10/11/2019

Dated

Addendum Number - 02

In accordance with OAR 340-216-0020, the following condition now read as follows (changes in greyscale highlight)

45. Applicable Requirement The permittee must operate all emergency stationary reciprocating internal combustion engines (RICE) in accordance with the requirements below: [40 CFR 63.6640(f)]
- 45.a. You must maintain records of when each emergency stationary RICE is operated, and the reasons for operation, as required by Condition 47.
 - 45.b. There is no time limit on the use of emergency stationary RICE in emergency situations.
 - 45.c. Operation of emergency stationary RICE for the purpose of maintenance checks and readiness testing (M&R testing) must be limited as follows: [See Note 1, below]
 - 45.c.i. for M&R testing, each emergency generator RICE may be operated for no more than 30 hours per year; [BACT, see Note 2, below]
 - 45.c.ii. for M&R testing, each fire pump RICE may be operated for no more than 50 hours per year; [BACT, see Note 2, below]
 - 45.c.iii. for M&R testing, a maximum of 10 emergency generator RICE may be operated in any single day at the Ronler Acres Campus; and
 - 45.c.iv. for M&R testing, emergency stationary RICE may only be operated during daytime between the hours of 8am to 6pm.

Note 1: Condition 45.c. is in lieu of the maintenance and readiness testing limit of 100 hours per year specified in 40 CFR 63.6640(f). Condition 45.c. may not be revised without first reviewing the air quality analysis, and if necessary conducting an air quality analysis to demonstrate that the change will continue to be protective of the short-term PM2.5 ambient air quality standard. [OAR 340-226-0120(1)]

Note 2: Conditions 45.c.i. and 45.c.ii. are BACT limits; BACT determination, Amendment to Major NSR permit 34-2681-ST-01 application no. 28014. Application received 12/31/2014, Amendment received 5/19/2015.