



**March 1, 2021**

Oregon Department of Environmental Quality  
 AQ Permit Coordinator  
 700 NE Multnomah Street, Ste 600  
 Portland, Oregon 97232

**Re: Intel Corporation, Aloha and Ronler Acres Campuses, ACDP 34-2681-ST-01  
 Calendar Year 2020 Annual Report**

In accordance with the requirements set forth in Oregon Department of Environmental Quality (ODEQ) Permit ACDP 34-2681-ST-01 Condition 77.b., Intel Corporation (Intel) is submitting three (3) copies of this annual report. During calendar year 2020, there was one bypass reported on March 5, 2020 related to a D1B scrubber bypass that occurred on February 22, 2020 that was not a result of malfunction or emergency. Therefore, this was a deviation of permit condition 37.c. There were no other instances of deviation from any permit requirements within the air permit #34-2681-ST-01. This annual report is being submitted in a timely manner on or before March 15, 2021 and includes the following:

- 77.b.ii.: The emission fee report
  - 77.b.iii.: A summary of the Excess Emissions and Upset log
  - 77.b.iv.: The annual certification that the risk management plan is being properly implemented
  - 77.b.v.: The type and amount of fuel combusted
  - 77.b.vi.: The calculated 12-month rolling emission rates for PM, PM<sub>10</sub>, PM<sub>2.5</sub>, SO<sub>2</sub>, CO, NO<sub>x</sub>, VOC, Fluorides, combined HAPs and individual HAPs
- NOTES:
- Reporting for individual HAPs is only required for pollutants with emission rates of 0.1 or more tons/yr.
  - The GHG emissions report will be submitted no later than March 31 as per OAR 340, Division 215.
- 77.b.vii.: Revisions of the pollutant capture efficiency function used for compliance emission calculations in condition 60.
  - 77.b.viii.: A summary of the physical changes, additions and/or process modifications as well as the pollution prevention project(s) performed to offset emission increases associated with these changes/modifications, pre-approved pursuant to Condition 16. In addition, the permittee must identify and summarize any change(s) with the associated emission increase of five (5) or more tons of VOC or one (1) or more tons of any HAP on a yearly basis.
  - 77.b.ix.: Summary of complaints relating to air quality received by permittee during the year.
  - 77.b.x.: List of major maintenance performed on pollution control equipment.
  - 77.b.xi.: There are no applicable Subpart Dc specific reporting requirements for affected facilities that are exclusively natural gas fired.

Intel Corporation  
 2501 NE Century Blvd  
 Hillsboro, OR 97124  
 www.intel.com

**77.b.ii.: Emission fee report:**

Attachment A to this annual report includes Form F1101 as the emission fee report.

**77.b.iii.: Summary of the Excess Emissions and Upset log:**

There were no excess emissions or upset events in calendar year 2020.

**77.b.iv.: Annual certification that the risk management plan (RMP) is being properly implemented:**

The Ronler Acres campus has an RMP that was last updated in June of 2020. The RMP is current and is implemented as required. The Aloha campus does not store regulated substances in quantities which exceed the RMP applicability threshold quantities, and therefore does not have an RMP.

**77.b.v.: The type and amount of fuel combusted:**

The Ronler Acres and Aloha campuses only combust natural gas and diesel fuel. The diesel fuel is fired within the emergency generators and fire pumps, while natural gas is fired in boilers, RCTOs, heaters, and Point of Use (POU) abatement devices. The quantity of these fuels combusted in 2020 are summarized below.

- Diesel Fuel Combusted
  - Aloha: 2,211 gallons
  - Ronler Acres: 45,904 gallons
  - Total: 48,115gallons
- Natural Gas Combusted
  - Aloha: 143 MMscf
  - Ronler Acres: 1,360 MMscf
  - Total: 1,502 MMscf

**77.b.vi.: Calculated 12-month rolling emissions:**

Attachment B to this annual report includes the calculated 12-month rolling emission rates for PM, PM<sub>10</sub>, PM<sub>2.5</sub>, SO<sub>2</sub>, CO, NO<sub>x</sub>, VOC, Fluorides, combined HAPs, and individual HAPs with annual emissions of 0.1 or more tons/yr. VOC emissions include both controlled and uncontrolled VOC emissions from the site.

**77.b.vii.: Revisions of the pollutant capture efficiency function used for compliance emission calculations in condition 60:**

No revisions were made to pollutant capture efficiencies used for compliance emission calculations in condition 60.

**77.b.viii.: Summary of physical changes pursuant to Condition 16:**

During calendar year 2020, there were no physical changes, additions and/or process modifications or associated pollution prevention projects performed to offset emission increases in accordance with Permit ACDP 34-2681-ST-01 Condition 16 regarding Operational Flexibility.

**77.b.ix.: Summary of complaints:**

During calendar year 2020, there were no formal complaints or inquiries.

**77.b.x.: List of major maintenance performed on pollution control equipment:**

Attachment C to this annual report includes a list of major maintenance performed on the RCTOs and scrubbers at the Ronler Acres and Aloha campuses. All maintenance records (major and minor) are maintained onsite within the Maximo system and available for inspection upon request.

**77.b.xi.: NSPS Subpart Dc reporting requirements:**


Intel continues to fire natural gas exclusively in all boilers at the Ronler Acres and Aloha campuses. Therefore, there are no applicable Subpart Dc reporting requirements.

**Statement of Certification (as required by Permit Condition 74):**

*Based on information and belief formed after reasonable inquiry, the statements and information in this document and any attachments are true, accurate and complete. I also certify that all statements made concerning compliance, which are based on monitoring required by the permit but not required to be submitted to DEQ, are true, accurate and complete based on information and belief formed after reasonable inquiry.*

Peng Bai  
Name of designated responsible official

Corporate Vice President  
Title of responsible official

DocuSigned by:  
  
723CC6994B37497...

March 1, 2021

Signature of responsible official

Date

Please contact me ([stephanie.b.shanley@intel.com](mailto:stephanie.b.shanley@intel.com); 503-319-6285) if you have any questions.

Sincerely,

DocuSigned by:  
  
2C247AE35E2D4EC...

Stephanie Shanley  
Environmental Manager  
INTEL CORPORATION

cc: Patty Jacobs, ODEQ  
Site Air Correspondence File

# Attachment A:

DEQ Form F1101



Total Emissions by Regulated Pollutant

FORM F1101

1. Reporting year: 2020	
2. Facility name: Intel Corporation - Aloha & Ronler Acres	4. Permit number: ACDP 34-2681-ST-01
3. Aloha Campus, 3585 SW 198th Ave, Aloha, OR 97007	5. Stephanie Shanley, Environmental Manager
Mailing street address or PO Box Ronler Acres, 2501 NE Century Blvd, Hillsboro, OR 97124	Contact name and title (503) 319-6285
Mailing city, state and ZIP code	Phone number with area code
6. Emissions (in tons) by regulated air pollutant subject to fees for the reporting year:	
PM <sub>10</sub> *	35
or PM	_____
or PM <sub>2.5</sub>	_____
or TSP	_____
SO <sub>2</sub>	39
NO <sub>x</sub> (as NO <sub>2</sub> )	197
VOC	178
* Report only one particulate category. If permit has a PSEL for PM <sub>10</sub> , report emissions of PM <sub>10</sub> . If permit has a PSEL for particulate matter (PM) and not PM <sub>10</sub> , report emissions of PM. If permit has a PSEL for PM <sub>2.5</sub> and not PM <sub>10</sub> or PM, report emissions of PM <sub>2.5</sub> . If permit has a PSEL for total suspended particulate (TSP) and not PM <sub>10</sub> , PM or PM <sub>2.5</sub> , report emissions of TSP.	
7. Total emissions (in tons) of pollutants subject to fees for the reporting year: <u>449</u>	
8. Statement of certification:	
I have reviewed this report and all supporting documentation in their entirety and to the best of my knowledge, information, and belief formed after reasonable inquiry, the statements and information contained herein are true, accurate and complete.	
<u>Peng Bai</u> Name of designated responsible official	<u>Corporate Vice President</u> Title of responsible official
DocuSigned by:  723CC6894B37497... Signature of responsible official	March 1, 2021 Date

# Attachment B:

Calendar Year 2020 12-Month Rolling Emission Inventory

Pollutant	Rolling 12-month Total Emissions (Ronler Acres and Aloha Facilities combined)												PSEL	Units
	Jan-20	Feb-20	Mar-20	Apr-20	May-20	Jun-20	Jul-20	Aug-20	Sep-20	Oct-20	Nov-20	Dec-20		
PM	26.4	25.6	26.3	25.8	25.9	25.2	25.5	25.1	25.7	25.5	24.4	24.9	41	tons per year
PM10	21.0	20.2	20.9	20.4	20.5	19.8	20.1	19.7	20.3	20.1	19.1	19.5	35	
PM2.5	16.7	16.0	16.6	16.1	16.2	15.6	15.8	15.5	16.1	15.9	14.8	15.2	31	
NOx	122.0	125.3	128.5	130.9	133.6	135.9	137.5	138.5	139.2	139.3	140.2	140.5	197	
CO	138.9	141.4	143.4	144.7	146.0	147.1	147.4	147.8	147.8	147.0	147.4	147.3	229	
SO2	4.0	4.1	4.3	4.4	4.6	4.7	4.9	5.0	5.1	5.4	5.4	5.6	39	
VOC	82.2	81.9	83.8	82.9	82.9	83.2	81.0	79.6	78.4	77.5	76.0	75.5	178	
Total Fluorides	4.4	4.2	4.1	3.9	3.7	3.6	3.4	3.2	3.0	2.8	2.6	2.3	6.4	
Total HAPs	10.0	9.8	9.6	9.3	9.0	8.6	8.3	8.0	7.7	7.4	6.9	6.5	24	
Individual HAP - HF	7.48	7.32	7.14	6.96	6.74	6.51	6.28	6.02	5.80	5.53	5.22	4.85	9	
Individual HAP - Cl2	1.83	1.69	1.54	1.36	1.21	0.96	0.79	0.69	0.50	0.36	0.14	0.01	9	
Individual HAP - HCl	0.47	0.54	0.61	0.67	0.75	0.82	0.90	0.98	1.03	1.11	1.17	1.21	9	
Individual HAP - COS	0.07	0.10	0.11	0.13	0.14	0.16	0.19	0.21	0.22	0.24	0.25	0.27	9	
GHG	369,969	378,578	387,187	395,797	404,406	413,015	421,625	430,234	438,843	447,453	456,062	464,671	819,000	

Notes:

\* All individual HAPs with annual emissions above 0.1 tons per year are reported above

# Attachment C:

List of Major Maintenance on RCTOs and Scrubbers in  
Calendar Year 2020



Site	Asset	Work Order Description	Date
AL-AFO	F15-SC7-2-12	F15 Process Scrubber #12 (Basement) F15-SC7-2-12, Sequenced	1/9/2020
AL-AFO	F15-SC7-1-2	F15 Acid Scrubber #2 (Sequenced) (Fab Impact: 773987)	2/5/2020
AL-AFO	F15-SC7-1-5	F15 Acid Scrubber #5, F15-SC7-1-5, Sequenced (Fab Impact: 774167)	2/12/2020
AL-AFO	F15-SC7-1-4	2020 ECP Inspection Complete - F15 Acid Scrubber #4, F15-SC7-1-4, Sequenced (Fab Impact:778404)	3/2/2020
AL-AFO	F15-SC7-1-4	F15 Acid Scrubber #4, F15-SC7-1-4, Sequenced (Fab Impact: 773989)	3/3/2020
AL-AFO	F15-SC7-1-1	F15 Acid Scrubber #1 (Fab Impact: #), F15-SC7-1-1, Sequenced (Fab Impact: 783232)	3/17/2020
AL-AFO	F15-SC7-1-6	F15 Acid Scrubber #6, F15-SC7-1-6, Sequenced (Fab Impact: 783232)	3/18/2020
AL-AFO	F15-AU138-2-10	F15 Munters 2, F15-AU138-2-10, Sequenced (Fab Impact: 784034)	3/22/2020
AL-AFO	F15-AU138-1-10	F15 Munters 1 (1Y, 6M, NN Fab Impact), F15-AU138-1-10, Sequenced	3/22/2020
AL-AFO	F15-SC7-1-3	F15 Acid Scrubber #3 (1Y PMs 1 scrubber FH and 1 BH), F15-SC7-1-3, Sequenced	3/22/2020
AL-AFO	F15-SC7-1-3	F15 Acid Scrubber #3 (1Y PMs 1 scrubber FH and 1 BH), F15-SC7-1-3, Sequenced (Fab Impact: 784974)	3/25/2020
AL-AFO	F15-SC7-2-12	F15 Process Scrubber #12 (Basement) F15-SC7-2-12, Sequenced	4/6/2020
AL-AFO	F15-SC7-1-2	F15 Acid Scrubber #2 (Sequenced) (Fab Impact: 785936)	4/24/2020
AL-AFO	F15-SC7-1-1	F15 Acid Scrubber #1 F15-SC7-1-1, Sequenced (Unit down, no Fab Impact needed)	5/11/2020
AL-AFO	F15-SC7-1-4	F15 Acid Scrubber #4, F15-SC7-1-4, Sequenced (Fab Impact:792909)	5/18/2020
AL-AFO	F15-AU138-2-10	2020 ECP complete F15 Munters 2, F15-AU138-2-10, Sequenced (Fab Impact: 792939)	6/8/2020
AL-AFO	F15-AU138-1-10	F15 Munters 1 (1Y, 6M, NN Fab Impact), F15-AU138-1-10, Sequenced (Fab Impact: 792933)	6/10/2020
AL-AFO	F15-SC7-1-3	F15 Acid Scrubber #3 (1Y PMs 1 scrubber FH and 1 BH), F15-SC7-1-3, Sequenced (Fab Impact: 797605)	6/29/2020
AL-AFO	F15-SC7-1-5	F15 Acid Scrubber #5, F15-SC7-1-5, Sequenced (Fab Impact: 797337)	7/7/2020
AL-AFO	F15-SC7-1-6	F15 Acid Scrubber #6, F15-SC7-1-6, Sequenced Fab Impact: 799547	7/17/2020
AL-AFO	F15-SC7-1-2	F15 Acid Scrubber #2 (Sequenced) (Fab Impact: 801897)	7/21/2020
AL-AFO	F15-SC7-1-1	F15 Acid Scrubber #1, F15-SC7-1-1, Sequenced (Fab Impact: 803072)	8/21/2020
AL-AFO	F15-SC7-1-4	F15 Acid Scrubber #4, F15-SC7-1-4, Sequenced (Fab Impact: 806281)	8/25/2020
AL-AFO	F15-AU138-1-10	F15 Munters 1 (1Y, 6M, NN Fab Impact), F15-AU138-1-10, Sequenced	9/1/2020
AL-AFO	F15-SC7-2-12	F15 Process Scrubber #12 (Basement) F15-SC7-2-12, Sequenced	9/2/2020
AL-AFO	F15-AU138-2-10	F15 Munters 2, F15-AU138-2-10, Sequenced	9/7/2020
AL-AFO	F15-SC7-1-3	F15 Acid Scrubber #3 (1Y PMs 1 scrubber FH and 1 BH), F15-SC7-1-3, Sequenced (Fab Impact: 812974)	9/23/2020
AL-AFO	F15-SC7-1-5	F15 Acid Scrubber #5, F15-SC7-1-5, Sequenced (Fab impact: 812956)	9/28/2020
AL-AFO	F15-SC7-1-6	F15 Acid Scrubber #6, F15-SC7-1-6, Sequenced (Fab Impact: 816134)	10/19/2020
AL-AFO	F15-SC7-1-2	F15 Acid Scrubber #2 (Sequenced) (Fab Impact: 824319)	11/4/2020
AL-AFO	F15-SC7-2-12	F15 Process Scrubber #12 (Basement) F15-SC7-2-12, Sequenced	11/16/2020
AL-AFO	F15-SC7-1-1	F15 Acid Scrubber #1 (Fab Impact: #), F15-SC7-1-1, Sequenced (Fab Impact: 827637)	12/4/2020
AL-AFO	F15-SC7-1-4	F15 Acid Scrubber #4, F15-SC7-1-4, Sequenced (Fab Impact: 827641)	12/10/2020
RA-D1C	RB1-SC133-2-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-2-111	1/3/2020
RA-D1C	D1C-AIT133-3-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1C-AIT133-3-09A	2/10/2020
RA-D1C	D1C-SC133-3-100	EXSC Scrubber Sequenced PM Hierarchy D1C-SC133-3-100	2/10/2020
RA-D1C	D1C-FIT133-3-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration D1C-FIT133-3-05A	2/12/2020
RA-D1C	D1C-SC133-1-200	EXSC Scrubber (Sequenced) PM D1C-SC133-1-200	2/26/2020
RA-D1C	D1C-TET-138-1-56A	VOC ANNUAL--Temperature Simulation Calibration D1C-TET-138-1-56A	2/29/2020
RA-D1C	D1C-FIT138-1-120	VOC ANNUAL--Flow Transmitter Calibration D1C-FIT138-1-120	2/29/2020
RA-D1C	D1C-VOC138-2-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-2-120	3/2/2020
RA-D1C	D1C-VOC138-2-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-2-120	3/4/2020
RA-D1C	D1C-TET-138-3-56A	VOC ANNUAL--Temperature Simulation Calibration D1C-TET-138-3-56A	3/7/2020
RA-D1C	D1C-FIT138-3-120	VOC ANNUAL--Flow Transmitter Calibration D1C-FIT138-3-120	3/7/2020
RA-D1C	RB1-SC133-8-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-8-111	3/9/2020
RA-D1C	D1C-VOC138-3-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-3-120	3/11/2020
RA-D1C	RB1-AIT133-7-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RB1-AIT133-7-09A	3/14/2020
RA-D1C	RB1-FIT133-7-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration RB1-FIT133-7-05A	3/14/2020
RA-D1C	RB1-SC133-7-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-7-111	3/14/2020
RA-D1C	D1C-VOC138-1-120	D1C VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	3/18/2020
RA-D1C	D1C-VOC138-2-120	D1C VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	3/18/2020
RA-D1C	D1C-VOC138-3-120	D1C VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	3/18/2020
RA-D1C	D1C-SC133-1-100	EXSC Scrubber Sequenced PM Hierarchy D1C-SC133-1-100	3/23/2020
RA-D1C	D1C-SC134-1-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM Job Plan D1C-SC134-1-100 eRequest: not required for Semi-Annual	4/16/2020
RA-D1C	RB1-AIT133-4-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RB1-AIT133-4-09A	4/17/2020
RA-D1C	RB1-FIT133-4-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration RB1-FIT133-4-05A	4/17/2020
RA-D1C	RB1-SC133-4-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-4-111	4/17/2020
RA-D1C	RB1-SC133-1-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-1-111	4/22/2020
RA-D1C	D1C-VOC138-3-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-3-120	4/29/2020

Site	Asset	Work Order Description	Date
RA-D1C	D1C-VOC138-1-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-1-120	4/29/2020
RA-D1C	RB1-AIT133-2-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RB1-AIT133-2-09A	5/3/2020
RA-D1C	RB1-FIT133-2-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration RB1-FIT133-2-05A	5/3/2020
RA-D1C	D1C-VOC138-1-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-1-120	5/7/2020
RA-D1C	D1C-SC134-2-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1C-SC134-2-00 (eRequest: not required for Semi-Annual))	5/8/2020
RA-D1C	D1C-SC133-4-100	EXSC Scrubber Sequenced PM Hierarchy D1C-SC133-4-100	5/16/2020
RA-D1C	D1C-VOC138-2-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-2-120	6/8/2020
RA-D1C	D1C-VOC138-3-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-3-120	6/14/2020
RA-D1C	RB1-AIT133-6-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RB1-AIT133-6-09A	6/27/2020
RA-D1C	RB1-FIT133-6-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration RB1-FIT133-6-05A	6/27/2020
RA-D1C	RB1-SC133-6-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-6-111	6/27/2020
RA-D1C	D1C-AIT133-2-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1C-AIT133-2-09A	7/3/2020
RA-D1C	D1C-FIT133-2-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration D1C-FIT133-2-05A	7/3/2020
RA-D1C	D1C-SC133-2-100	EXSC Scrubber Sequenced PM Hierarchy D1C-SC133-2-100	7/3/2020
RA-D1C	RB1-SC133-2-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-2-111	7/23/2020
RA-D1C	D1C-VOC138-1-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-1-120	7/26/2020
RA-D1C	D1C-SC133-3-100	EXSC Scrubber Sequenced PM Hierarchy D1C-SC133-3-100	8/15/2020
RA-D1C	RB1-SC133-7-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-7-111	8/24/2020
RA-D1C	D1C-SC133-1-200	(9am start) EXSC Scrubber (Sequenced) PM D1C-SC133-1-200	9/6/2020
RA-D1C	RB1-SC133-8-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-8-111	9/27/2020
RA-D1C	D1C-VOC138-3-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-3-120	10/12/2020
RA-D1C	D1C-AIT133-1-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1C-AIT133-1-09A	10/12/2020
RA-D1C	D1C-SC133-1-100	EXSC Scrubber Sequenced PM Hierarchy D1C-SC133-1-100	10/12/2020
RA-D1C	D1C-SC134-1-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM Job Plan D1C-SC134-1-100 (eRequest 819569 submitted for 9-11am)	10/17/2020
RA-D1C	D1C-VOC138-2-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-2-120	10/26/2020
RA-D1C	D1C-VOC138-1-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-1-120	11/4/2020
RA-D1C	D1C-TET-138-2-56A	VOC ANNUAL--Temperature Simulation Calibration D1C-TET-138-2-56A	11/11/2020
RA-D1C	D1C-FIT138-2-120	VOC ANNUAL--Flow Transmitter Calibration D1C-FIT138-2-120	11/11/2020
RA-D1C	RB1-AIT133-1-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RB1-AIT133-1-09A	11/14/2020
RA-D1C	RB1-SC133-1-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-1-111	11/14/2020
RA-D1C	RB1-SC133-4-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-4-111	11/16/2020
RA-D1C	D1C-SC133-2-100	EXSC Scrubber Sequenced PM Hierarchy D1C-SC133-2-100	11/23/2020
RA-D1C	RB1-SC133-2-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-2-111	11/30/2020
RA-D1C	D1C-VOC138-2-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-2-120	12/9/2020
RA-D1C	D1C-VOC138-3-120	VOC Abatement System (EXVO) (Sequenced) PM D1C-VOC138-3-120	12/11/2020
RA-D1C	RB1-SC133-6-111	EXSC Scrubber Sequenced PM Hierarchy RB1-SC133-6-111	12/20/2020
RA-D1D	AIT133-3-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration AIT133-3-09A	1/4/2020
RA-D1D	SC-133-3-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-3-100	1/4/2020
RA-D1D	FIT133-3-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration FIT133-3-05A	1/9/2020
RA-D1D	SC-133-4-100	EXSC Scrubber Sequenced PM Hierarchy (Hierarchy) SC-133-4-100	1/11/2020
RA-D1D	RP1-AIT133-1-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RP1-AIT133-1-09A	1/14/2020
RA-D1D	RP1-SC133-1-100	EXSC Scrubber Sequenced PM Hierarchy RP1-SC133-1-100	1/14/2020
RA-D1D	VOC138-4-120	VOC Abatement System (EXVO) (Sequenced) PM VOC138-4-120	1/15/2020
RA-D1D	VOC-138-1-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-1-120	1/26/2020
RA-D1D	FIT138-1-20A	VOC ANNUAL--Flow Transmitter Calibration FIT138-1-20A	1/27/2020
RA-D1D	RP1-FIT133-1-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration RP1-FIT133-1-05A	1/28/2020
RA-D1D	SC-133-1-200	EXSC Scrubber(Sequenced) PM SC-133-1-200	1/30/2020
RA-D1D	VOC-138-2-120	D1D VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	2/18/2020
RA-D1D	VOC-138-1-120	D1D VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	2/19/2020
RA-D1D	VOC-138-3-120	D1D VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	2/19/2020
RA-D1D	VOC138-4-120	D1D VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	2/19/2020
RA-D1D	SC134-3-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM SC134-3-100	2/20/2020
RA-D1D	VOC-138-2-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-2-120	2/25/2020
RA-D1D	RP1-SC133-2-100	EXSC Scrubber Sequenced PM Hierarchy RP1-SC133-2-100	3/1/2020
RA-D1D	AIT133-5-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration AIT133-5-09A	3/13/2020
RA-D1D	FIT133-5-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration FIT133-5-05A	3/13/2020
RA-D1D	SC-133-5-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-5-100	3/13/2020
RA-D1D	VOC-138-3-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-3-120	3/30/2020

Site	Asset	Work Order Description	Date
RA-D1D	SC-133-6-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-6-100	4/4/2020
RA-D1D	SC-134-2-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM SC-134-2-100	4/5/2020
RA-D1D	SC-133-1-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-1-100	4/6/2020
RA-D1D	SC-134-1-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM SC-134-1-100	4/9/2020
RA-D1D	VOC-138-1-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-1-120	4/13/2020
RA-D1D	AIT133-2-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration AIT133-2-09A	4/21/2020
RA-D1D	FIT133-2-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration FIT133-2-05A	4/21/2020
RA-D1D	SC-133-2-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-2-100	4/21/2020
RA-D1D	SC-133-3-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-3-100	4/27/2020
RA-D1D	VOC138-4-120	VOC Abatement System (EXVO) (Sequenced) PM VOC138-4-120	4/29/2020
RA-D1D	RP1-SC133-1-100	EXSC Scrubber Sequenced PM Hierarchy RP1-SC133-1-100	5/2/2020
RA-D1D	RP1-SC134-1-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM RP1-SC134-1-100	5/7/2020
RA-D1D	VOC-138-2-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-2-120	5/16/2020
RA-D1D	VOC-138-3-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-3-120	6/16/2020
RA-D1D	SC-133-1-200	EXSC Scrubber(Sequenced) PM SC-133-1-200	7/15/2020
RA-D1D	VOC-138-1-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-1-120 (FYI eRequest 804843)	7/25/2020
RA-D1D	SC134-3-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM SC134-3-100	8/2/2020
RA-D1D	AIT133-4-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration AIT133-4-09A	8/9/2020
RA-D1D	SC-133-4-100	EXSC Scrubber Sequenced PM Hierarchy (Hierarchy) SC-133-4-100	8/9/2020
RA-D1D	VOC138-4-120	VOC Abatement System (EXVO) (Sequenced) PM VOC138-4-120 (Factory FYI eRequest 806771)	8/13/2020
RA-D1D	VOC-138-2-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-2-120	8/26/2020
RA-D1D	SC-133-5-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-5-100	9/9/2020
RA-D1D	RP1-AIT133-2-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RP1-AIT133-2-09A	9/18/2020
RA-D1D	RP1-SC133-2-100	EXSC Scrubber Sequenced PM Hierarchy RP1-SC133-2-100	9/18/2020
RA-D1D	AIT133-3-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration AIT133-3-09A	9/23/2020
RA-D1D	SC-133-3-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-3-100	9/23/2020
RA-D1D	VOC138-4-120	VOC Abatement System (EXVO) (Sequenced) PM VOC138-4-120	10/5/2020
RA-D1D	VOC-138-1-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-1-120	10/5/2020
RA-D1D	SC-134-2-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM SC-134-2-100	10/7/2020
RA-D1D	SC-134-1-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM SC-134-1-100	10/12/2020
RA-D1D	AIT133-6-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration AIT133-6-09A	10/31/2020
RA-D1D	SC-133-6-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-6-100	10/31/2020
RA-D1D	AIT133-1-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration AIT133-1-09A	11/8/2020
RA-D1D	SC-133-1-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-1-100	11/8/2020
RA-D1D	VOC-138-3-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-3-120	11/16/2020
RA-D1D	RP1-AIT133-1-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration RP1-AIT133-1-09A	11/18/2020
RA-D1D	RP1-SC133-1-100	EXSC Scrubber Sequenced PM Hierarchy RP1-SC133-1-100	11/18/2020
RA-D1D	VOC-138-2-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-2-120	11/19/2020
RA-D1D	SC-133-2-100	EXSC Scrubber Sequenced PM Hierarchy SC-133-2-100	11/23/2020
RA-D1D	VOC-138-3-120	VOC Abatement System (EXVO) (Sequenced) PM VOC-138-3-120	12/17/2020
RA-D1X	D1X-VOC138-3-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-3-20	12/31/2019
RA-D1X	D1X-AIT133-3-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X-AIT133-3-09A	1/18/2020
RA-D1X	D1X-FIT133-3-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration D1X-FIT133-3-05A	1/18/2020
RA-D1X	D1X-SC133-3-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-3-00	1/18/2020
RA-D1X	D1X-VOC138-6-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-6-20	1/19/2020
RA-D1X	D1X-VOC138-5-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-5-20	1/20/2020
RA-D1X	D1X-SC133-1-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-1-00	1/20/2020
RA-D1X	D1X-VOC138-7-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-7-20	1/22/2020
RA-D1X	D1X-VOC138-2-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-2-20	1/25/2020
RA-D1X	D1X2A-VOC138-2-20	Ronler Acers VOC Abatement System (EXVO) Sequenced PM Job Plan D1X2A-VOC138-2-20	1/29/2020
RA-D1X	D1X-SC133-5-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC133-5-00	2/2/2020
RA-D1X	D1X-VOC138-1-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-1-20	2/13/2020
RA-D1X	D1X-FIT138-1-20A	VOC ANNUAL--Flow Transmitter Calibration D1X-FIT138-1-20A	2/14/2020
RA-D1X	D1X2A-SC134-2-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-2-00	2/17/2020
RA-D1X	D1X-VOC138-4-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-4-20	2/19/2020
RA-D1X	D1X2A-AIT133-2-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X2A-AIT133-2-09A	2/19/2020
RA-D1X	D1X2A-FIT133-2-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration D1X2A-FIT133-2-05A	2/19/2020

Site	Asset	Work Order Description	Date
RA-D1X	D1X2A-SC133-2-00	EXSC Scrubber Sequenced PM Hierarchy D1X2A-SC133-2-00	2/19/2020
RA-D1X	D1X2A-SC134-4-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-4-00	2/23/2020
RA-D1X	D1X-SC134-2-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-2-00	2/26/2020
RA-D1X	D1X-VOC138-2-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-2-20	3/8/2020
RA-D1X	D1X-VOC138-5-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-5-20	4/2/2020
RA-D1X	D1X-VOC138-6-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-6-20	4/3/2020
RA-D1X	D1X2A-FIT138-1-20A	VOC ANNUAL--Flow Transmitter 2 Year Calibration D1X2A-FIT8-1-20A	4/9/2020
RA-D1X	D1X-SC134-4-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-4-00	4/9/2020
RA-D1X	D1X-SC133-4-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-4-00	4/9/2020
RA-D1X	D1X-VOC138-3-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-3-20	4/10/2020
RA-D1X	D1X-VOC138-4-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-4-20	4/11/2020
RA-D1X	D1X2A-FIT138-2-20A	VOC ANNUAL--Flow Transmitter 2 Year Calibration D1X2A-FIT8-2-20A	4/13/2020
RA-D1X	D1X-VOC138-2-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-2-20	4/14/2020
RA-D1X	D1X-VOC138-5-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-5-20	4/15/2020
RA-D1X	D1X-FIT138-5-20A	VOC ANNUAL--Flow Transmitter Calibration D1X-FIT138-5-20A	4/15/2020
RA-D1X	D1X-SC134-1-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-1-00	4/23/2020
RA-D1X	PUB1-SC133-1-00	EXSC Scrubber (Sequenced) PM PUB1-SC133-1-00	4/24/2020
RA-D1X	D1X-AIT133-2-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X-AIT133-2-09A	5/1/2020
RA-D1X	D1X2A-SC134-3-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-3-00	5/1/2020
RA-D1X	D1X-SC133-2-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-2-00	5/1/2020
RA-D1X	D1X-SC134-3-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-3-00	5/4/2020
RA-D1X	D1X2A-SC133-4-00	EXSC Scrubber Sequenced PM Hierarchy D1X2A-SC133-4-00	5/7/2020
RA-D1X	D1X2A-FIT133-3-05A	SCRUBBER ANNUAL--Flow Transmitter Calibration D1X2A-FIT133-3-05A	5/9/2020
RA-D1X	D1X2A-AIT133-3-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X2A-AIT133-3-09A	5/13/2020
RA-D1X	D1X2A-SC133-3-00	EXSC Scrubber Sequenced PM Hierarchy D1X2A-SC133-3-00	5/13/2020
RA-D1X	D1X-VOC138-1-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-1-20	5/16/2020
RA-D1X	D1X2A-SC134-1-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-1-00	5/18/2020
RA-D1X	D1X2A-VOC138-1-20	Ronler Acers VOC Abatement System (EXVO) Sequenced PM Job Plan D1X2A-VOC138-1-20	6/24/2020
RA-D1X	D1X-VOC138-3-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-3-20	7/6/2020
RA-D1X	D1X-VOC138-6-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-6-20	7/25/2020
RA-D1X	D1X-VOC138-5-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-5-20	7/26/2020
RA-D1X	D1X-VOC138-4-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-4-20	7/26/2020
RA-D1X	D1X-VOC138-2-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-2-20	7/26/2020
RA-D1X	D1X-VOC138-7-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-7-20	7/28/2020
RA-D1X	D1X2A-VOC138-2-20	Ronler Acers VOC Abatement System (EXVO) Sequenced PM Job Plan D1X2A-VOC138-2-20	8/3/2020
RA-D1X	D1X-AIT133-1-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X-AIT133-1-09A	8/12/2020
RA-D1X	D1X-SC133-1-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-1-00	8/12/2020
RA-D1X	D1X-SC133-3-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-3-00	8/18/2020
RA-D1X	D1X2A-SC133-2-00	EXSC Scrubber Sequenced PM Hierarchy D1X2A-SC133-2-00	8/19/2020
RA-D1X	D1X-SC133-5-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC133-5-00	8/26/2020
RA-D1X	D1X-VOC138-1-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-1-20	9/20/2020
RA-D1X	D1X-SC134-4-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-4-00	9/22/2020
RA-D1X	D1X-SC134-2-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-2-00	9/25/2020
RA-D1X	D1X2A-SC134-2-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-2-00	9/28/2020
RA-D1X	D1X2A-SC134-4-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-4-00	9/30/2020
RA-D1X	D1X-VOC138-6-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-6-20	10/5/2020
RA-D1X	D1X-AIT133-5-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X-AIT133-5-09A	10/12/2020
RA-D1X	D1X-AIT133-4-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X-AIT133-4-09A	10/13/2020
RA-D1X	D1X-SC133-4-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-4-00	10/13/2020
RA-D1X	D1X-VOC138-2-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-2-20	11/2/2020
RA-D1X	D1X2A-VOC138-2-20	Ronler Acers VOC Abatement System (EXVO) Sequenced PM Job Plan D1X2A-VOC138-2-20	11/8/2020
RA-D1X	D1X-SC133-2-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-2-00	11/9/2020
RA-D1X	D1X-VOC138-5-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-5-20	11/10/2020
RA-D1X	D1X-VOC138-3-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-3-20	11/11/2020
RA-D1X	D1X2A-SC134-3-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-3-00	11/15/2020
RA-D1X	D1X2A-SC133-3-00	EXSC Scrubber Sequenced PM Hierarchy D1X2A-SC133-3-00	11/15/2020
RA-D1X	D1X-SC134-1-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-1-00	11/17/2020
RA-D1X	D1X2A-SC134-1-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X2A-SC134-1-00	11/17/2020
RA-D1X	D1X-VOC138-1-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-1-20	11/19/2020
RA-D1X	D1X-VOC138-7-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-7-20	11/22/2020

Site	Asset	Work Order Description	Date
RA-D1X	D1X-SC134-3-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM D1X-SC134-3-00	11/24/2020
RA-D1X	D1X-VOC138-4-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-4-20	12/2/2020
RA-D1X	D1X2A-AIT133-4-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1X2A-AIT133-4-09A	12/5/2020
RA-D1X	D1X2A-SC133-5-00	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced), D1X2A-SC133-5-00	12/5/2020
RA-D1X	D1X2A-SC133-4-00	EXSC Scrubber Sequenced PM Hierarchy D1X2A-SC133-4-00	12/6/2020
RA-D1X	D1X-VOC138-7-20	VOC Abatement System (EXVO) (Sequenced) PM D1X-VOC138-7-20	12/16/2020
RA-D1X	D1X-SC133-1-00	EXSC Scrubber Sequenced PM Hierarchy D1X-SC133-1-00	12/20/2020
RA-D1X	D1X2A-VOC138-1-20	Ronler Acers VOC Abatement System (EXVO) Sequenced PM Job Plan D1X2A-VOC138-1-20	12/24/2020
RA-F20	F20-SC133-2-111	EXSC Scrubber Sequenced PM Hierarchy F20-SC133-2-111	1/2/2020
RA-F20	D1B-VOC138-1-22	D1B VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	2/3/2020
RA-F20	D1B-VOC138-2-22	D1B VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	2/3/2020
RA-F20	D1B-VOC-138-3-22	D1B VOC Abatement System (EXVO) (Sequenced) PM--ROUTE	2/3/2020
RA-F20	D1B-AIT133-3-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1B-AIT133-3-09A	2/21/2020
RA-F20	F20-SC133-3-111	EXSC Scrubber Sequenced PM Hierarchy F20-SC133-3-111	2/21/2020
RA-F20	D1B-VOC-138-3-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC-138-3-22	2/23/2020
RA-F20	D1B-FIT133-3-05	SCRUBBER ANNUAL--Flow Transmitter Calibration D1B-FIT133-3-05	3/18/2020
RA-F20	D1B-VOC-138-3-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC-138-3-22	4/1/2020
RA-F20	D1B-VOC138-2-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC138-2-22	4/2/2020
RA-F20	D1B-VOC138-2-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC138-2-22	4/3/2020
RA-F20	D1B-VOC138-1-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC138-1-22	4/8/2020
RA-F20	F20-SC133-1-111	EXSC Scrubber Sequenced PM Hierarchy F20-SC133-1-111	4/20/2020
RA-F20	F20-SC-134-1-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM F20-SC-134-1-100	4/24/2020
RA-F20	D1B-AIT133-2-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1B-AIT133-2-09A	4/28/2020
RA-F20	D1B-FIT133-2-05	SCRUBBER ANNUAL--Flow Transmitter Calibration D1B-FIT133-2-05	4/28/2020
RA-F20	F20-SC133-2-111	EXSC Scrubber Sequenced PM Hierarchy F20-SC133-2-111	4/28/2020
RA-F20	D1B-VOC-138-3-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC-138-3-22	7/6/2020
RA-F20	D1B-VOC138-2-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC138-2-22	7/31/2020
RA-F20	F20-SC133-3-111	EXSC Scrubber Sequenced PM Hierarchy F20-SC133-3-111	9/8/2020
RA-F20	D1B-VOC138-2-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC138-2-22	10/5/2020
RA-F20	D1B-VOC-138-3-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC-138-3-22	10/18/2020
RA-F20	F20-SC133-2-111	EXSC Scrubber Sequenced PM Hierarchy F20-SC133-2-111	11/3/2020
RA-F20	D1B-AIT133-1-09A	SCRUBBER ANNUAL--Rosemount Model 56 pH/Conductivity Transmitter Calibration D1B-AIT133-1-09A	11/16/2020
RA-F20	F20-SC133-1-111	EXSC Scrubber Sequenced PM Hierarchy F20-SC133-1-111	11/29/2020
RA-F20	F20-SC-134-1-100	Ronler Acers Scrubbed Exhaust (EXSC) Scrubber (Sequenced) PM F20-SC-134-1-100	12/1/2020
RA-F20	D1B-VOC-138-3-22	VOC Abatement System (EXVO) (Sequenced) PM D1B-VOC-138-3-22	12/24/2020